



**EDB Information Disclosure Requirements
Information Templates
for
Schedules 11a–13**

Company Name	Marlborough Lines
Disclosure Date	31 March 2016
AMP Planning Period Start Date (first day)	1 April 2016

Templates for Schedules 11a–13 (Asset Management Plan)
Template Version 4.1. Prepared 24 March 2015

Table of Contents

Information disclosure asset management plan schedules

Schedule	Schedule name
11a	REPORT ON FORECAST CAPITAL EXPENDITURE
11b	REPORT ON FORECAST OPERATIONAL EXPENDITURE
12a	REPORT ON ASSET CONDITION
12b	REPORT ON FORECAST CAPACITY
12c	REPORT ON FORECAST NETWORK DEMAND
12d	REPORT FORECAST INTERRUPTIONS AND DURATION
13	REPORT ON ASSET MANAGEMENT MATURITY

Disclosure Template Instructions

These templates have been prepared for use by EDBs when making disclosures under subclauses 2.6.1(1)(d), 2.6.1(1)(e), 2.6.1(2), 2.6.5(6), 2.6.6(1) and 2.6.6(2) of the Electricity Distribution Information Disclosure Determination 2012. The EDB may include a completed Schedule 13: Report on Asset Management Maturity table with its disclosures made under subclause 2.6.6(1) and 2.6.6(2), but this is not required. Schedule 13 tables that are not completed should be removed from disclosures made under subclause 2.6.6(1) and 2.6.6(2).

Company Name and Dates

To prepare the templates for disclosure, the supplier's company name should be entered in cell C8, the date of the first day of the 10 year planning period should be entered in cell C12, and the date on which the information is disclosed should be entered in cell C10 of the CoverSheet worksheet.

The cell C12 entry (planning period start date) is used to calculate disclosure years in the column headings that show above some of the tables. It is also used to calculate the AMP planning period dates in the template title blocks (the title blocks are the light green shaded areas at the top of each template).

The cell C8 entry (company name) is used in the template title blocks.

Dates should be entered in day/month/year order (Example -"1 April 2013").

Data Entry Cells and Calculated Cells

Data entered into this workbook may be entered only into the data entry cells. Data entry cells are the bordered, unshaded areas (white cells) in each template. Under no circumstances should data be entered into the workbook outside a data entry cell.

In some cases, where the information for disclosure is able to be ascertained from disclosures elsewhere in the workbook, such information is disclosed in a calculated cell.

Validation Settings on Data Entry Cells

To maintain a consistency of format and to guard against errors in data entry, some data entry cells test entries for validity and accept only a limited range of values. For example, entries may be limited to a list of category names or to values between 0% and 100%. Where this occurs, a validation message will appear when data is being entered.

Conditional Formatting Settings on Data Entry Cells

Schedule 12a columns G to K contains conditional formatting. The cells will change colour if the row totals do not add to 100%.

Inserting Additional Rows

The templates for schedules 11a, 12b and 12c may require additional rows to be inserted in tables marked 'include additional rows if needed'.

Additional rows must not be inserted directly above the first row or below the last row of a table. This is to ensure that entries made in the new row are included in the totals.

For schedule 12b the formula for column J (Utilisation of Installed Firm Capacity %) will need to be copied into the inserted row(s).

Column A schedule references should not be entered in additional rows.

Schedule References

The references labelled 'sch ref' in the leftmost column of each template are consistent with the row references in the Electricity Distribution ID Determination 2012 (as issued on 24 March 2015). They provide a common reference between the rows in the determination and the template.

Description of Calculation References

Calculation cell formulas contain links to other cells within the same template or elsewhere in the workbook. Key cell references are described in a column to the right of each template. These descriptions are provided to assist data entry. Cell references refer to the row of the template and not the schedule reference.

Company Name **Marlborough Lines**
 AMP Planning Period **1 April 2016 – 31 March 2026**

SCHEDULE 11a: REPORT ON FORECAST CAPITAL EXPENDITURE

This schedule requires a breakdown of forecast expenditure on assets for the current disclosure year and a 10 year planning period. The forecasts should be consistent with the supporting information set out in the AMP. The forecast is to be expressed in both constant price and nominal dollar terms. Also required is a forecast of the value of commissioned assets (i.e., the value of RAB additions)
 EDBs must provide explanatory comment on the difference between constant price and nominal dollar forecasts of expenditure on assets in Schedule 14a (Mandatory Explanatory Notes).
 This information is not part of audited disclosure information.

sch ref		Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5	CY+6	CY+7	CY+8	CY+9	CY+10
		for year ended 31 Mar 16	31 Mar 17	31 Mar 18	31 Mar 19	31 Mar 20	31 Mar 21	31 Mar 22	31 Mar 23	31 Mar 24	31 Mar 25	31 Mar 26
9	11a(i): Expenditure on Assets Forecast	\$000 (in nominal dollars)										
10	Consumer connection	466	505	408	412	412	412	416	420	425	429	433
11	System growth	-	-	-	-	-	-	156	158	159	161	162
12	Asset replacement and renewal	6,605	6,030	4,335	5,976	6,311	6,208	6,868	7,462	7,537	7,612	7,688
13	Asset relocations	39	429	2,244	979	1,442	618	624	210	212	214	217
14	Reliability, safety and environment:											
15	Quality of supply	2,083	1,470	2,270	2,061	1,339	1,648	1,093	1,104	1,115	1,126	1,137
16	Legislative and regulatory	98	338	51	52	52	52	52	53	53	54	54
17	Other reliability, safety and environment	320	1,348	683	768	768	768	1,041	526	531	536	541
18	Total reliability, safety and environment	2,501	3,156	3,004	2,880	2,158	2,468	2,185	1,682	1,698	1,715	1,733
19	Expenditure on network assets	9,611	10,120	9,992	10,246	10,324	9,705	10,250	9,932	10,031	10,132	10,233
20	Expenditure on non-network assets	1,905	1,981	1,969	1,494	1,494	1,494	1,509	1,524	1,539	1,555	1,570
21	Expenditure on assets	11,516	12,101	11,961	11,740	11,818	11,199	11,759	11,456	11,571	11,686	11,803
22												
23	plus Cost of financing	-	-	-	-	-	-	-	-	-	-	-
24	less Value of capital contributions	-	-	-	-	-	-	-	-	-	-	-
25	plus Value of vested assets	-	-	-	-	-	-	-	-	-	-	-
26												
27	Capital expenditure forecast	11,516	12,101	11,961	11,740	11,818	11,199	11,759	11,456	11,571	11,686	11,803
28												
29	Assets commissioned	11,516	12,101	11,961	11,740	11,818	11,199	11,759	11,456	11,571	11,686	11,803
30												
31												
32												
33												
34												
35												
36												
37												
38												
39												
40												
41												
42												
43												
44												
45												
46	Subcomponents of expenditure on assets (where known)											
47	Energy efficiency and demand side management, reduction of energy losses											
48	Overhead to underground conversion											
49	Research and development											

Company Name **Marlborough Lines**
 AMP Planning Period **1 April 2016 – 31 March 2026**

SCHEDULE 11a: REPORT ON FORECAST CAPITAL EXPENDITURE

This schedule requires a breakdown of forecast expenditure on assets for the current disclosure year and a 10 year planning period. The forecasts should be consistent with the supporting information set out in the AMP. The forecast is to be expressed in both constant price and nominal dollar terms. Also required is a forecast of the value of commissioned assets (i.e., the value of RAB additions)
 EDBs must provide explanatory comment on the difference between constant price and nominal dollar forecasts of expenditure on assets in Schedule 14a (Mandatory Explanatory Notes).
 This information is not part of audited disclosure information.

sch ref		Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5	CY+6	CY+7	CY+8	CY+9	CY+10
		for year ended 31 Mar 16	31 Mar 17	31 Mar 18	31 Mar 19	31 Mar 20	31 Mar 21	31 Mar 22	31 Mar 23	31 Mar 24	31 Mar 25	31 Mar 26
50												
51												
52												
53	Difference between nominal and constant price forecasts	\$000										
54	Consumer connection	-	5	8	12	12	12	16	20	25	29	33
55	System growth	-	-	-	-	-	-	6	8	9	11	12
56	Asset replacement and renewal	-	60	85	176	186	183	268	362	437	512	588
57	Asset relocations	-	4	44	29	42	18	24	10	12	14	17
58	Reliability, safety and environment:											
59	Quality of supply	-	15	45	61	39	48	43	54	65	76	87
60	Legislative and regulatory	-	3	1	2	2	2	2	3	3	4	4
61	Other reliability, safety and environment	-	13	13	23	23	23	41	26	31	36	41
62	Total reliability, safety and environment	-	31	59	85	63	73	85	82	98	115	133
63	Expenditure on network assets	-	100	197	301	304	285	400	482	581	682	783
64	Expenditure on non-network assets	-	20	39	44	44	44	59	74	89	105	120
65	Expenditure on assets	-	120	236	345	348	329	459	556	671	786	903
66												
67												
68	11a(ii): Consumer Connection											
69	Consumer types defined by EDB*	\$000 (in constant prices)										
70	all	466	500	400	400	400	400	400				
71												
72												
73												
74												
75	*include additional rows if needed											
76	Consumer connection expenditure	466	500	400	400	400	400	400				
77	less Capital contributions funding consumer connection	-	-	-	-	-	-	-				
78	Consumer connection less capital contributions	466	500	400	400	400	400	400				
79	11a(iii): System Growth											
80	Subtransmission	-	-	-	-	-	-	-	-	-	-	-
81	Zone substations	-	-	-	-	-	-	-	-	-	-	-
82	Distribution and LV lines	-	-	-	-	-	-	-	-	-	-	-
83	Distribution and LV cables	-	-	-	-	-	-	-	-	-	-	-
84	Distribution substations and transformers	-	-	-	-	-	-	-	-	-	-	-
85	Distribution switchgear	-	-	-	-	-	-	-	-	-	-	-
86	Other network assets	-	-	-	-	-	-	-	-	-	-	-
87	System growth expenditure	-	-	-	-	-	-	-	-	-	-	-
88	less Capital contributions funding system growth	-	-	-	-	-	-	-	-	-	-	-
89	System growth less capital contributions	-	-	-	-	-	-	-	-	-	-	-
90												

Company Name **Marlborough Lines**
 AMP Planning Period **1 April 2016 – 31 March 2026**

SCHEDULE 11a: REPORT ON FORECAST CAPITAL EXPENDITURE

This schedule requires a breakdown of forecast expenditure on assets for the current disclosure year and a 10 year planning period. The forecasts should be consistent with the supporting information set out in the AMP. The forecast is to be expressed in both constant price and nominal dollar terms. Also required is a forecast of the value of commissioned assets (i.e., the value of RAB additions)
 EDBs must provide explanatory comment on the difference between constant price and nominal dollar forecasts of expenditure on assets in Schedule 14a (Mandatory Explanatory Notes).
 This information is not part of audited disclosure information.

sch ref

	Current Year CY for year ended	CY+1 31 Mar 17	CY+2 31 Mar 18	CY+3 31 Mar 19	CY+4 31 Mar 20	CY+5 31 Mar 21
91						
92						
93	11a(iv): Asset Replacement and Renewal					
	\$000 (in constant prices)					
94	1,683	1,800	1,500	600	600	600
95	2,449	500	600	950	900	900
96	1,832	2,630	1,575	2,650	2,775	3,000
97	-	300	100	750	450	400
98	69	450	75	400	575	300
99	453	290	400	450	825	825
100	119	-	-	-	-	-
101	6,605	5,970	4,250	5,800	6,125	6,025
102	less					
103	Asset replacement and renewal less capital contributions					
104	6,605	5,970	4,250	5,800	6,125	6,025

	Current Year CY for year ended	CY+1 31 Mar 17	CY+2 31 Mar 18	CY+3 31 Mar 19	CY+4 31 Mar 20	CY+5 31 Mar 21
105						
106						
107	11a(v): Asset Relocations					
	\$000 (in constant prices)					
108	<i>Project or programme*</i>					
109	Underground conversions	8	225	2,200	950	1,400
110	Roading Authority Relocations	28	-	-	-	-
111	Forestry Relocations	-	-	-	-	-
112	Other relocations	4	200	-	-	-
113						
114	<i>*Include additional rows if needed</i>					
115	All other project or programmes - asset relocations					
116	Asset relocations expenditure	39	425	2,200	950	1,400
117	less					
118	Asset relocations less capital contributions	39	425	2,200	950	1,400
119						

	Current Year CY for year ended	CY+1 31 Mar 17	CY+2 31 Mar 18	CY+3 31 Mar 19	CY+4 31 Mar 20	CY+5 31 Mar 21
120						
121						
122	11a(vi): Quality of Supply					
	\$000 (in constant prices)					
123	<i>Project or programme*</i>					
124	SCADA	121	190	200	200	200
125	Network Automation	188	525	1,275	1,250	800
126	Digital Radio Network	434	75	250	-	-
127						
128						
129	<i>*Include additional rows if needed</i>					
130	All other projects or programmes - quality of supply					
131	Quality of supply expenditure	1,339	665	500	550	300
132	less					
133	Quality of supply less capital contributions	2,083	1,455	2,225	2,000	1,300
134						

Company Name **Marlborough Lines**
 AMP Planning Period **1 April 2016 – 31 March 2026**

SCHEDULE 11a: REPORT ON FORECAST CAPITAL EXPENDITURE

This schedule requires a breakdown of forecast expenditure on assets for the current disclosure year and a 10 year planning period. The forecasts should be consistent with the supporting information set out in the AMP. The forecast is to be expressed in both constant price and nominal dollar terms. Also required is a forecast of the value of commissioned assets (i.e., the value of RAB additions)
 EDBs must provide explanatory comment on the difference between constant price and nominal dollar forecasts of expenditure on assets in Schedule 14a (Mandatory Explanatory Notes).
 This information is not part of audited disclosure information.

sch ref

	Current Year CY for year ended 31 Mar 16	CY+1 31 Mar 17	CY+2 31 Mar 18	CY+3 31 Mar 19	CY+4 31 Mar 20	CY+5 31 Mar 21
11a(vii): Legislative and Regulatory						
<i>Project or programme*</i>						
\$000 (in constant prices)						
General	98	335	50	50	50	50
<i>*Include additional rows if needed</i>						
All other projects or programmes - legislative and regulatory						
Legislative and regulatory expenditure	98	335	50	50	50	50
less Capital contributions funding legislative and regulatory						
Legislative and regulatory less capital contributions	98	335	50	50	50	50
11a(viii): Other Reliability, Safety and Environment						
<i>Project or programme*</i>						
\$000 (in constant prices)						
Earthing (NERS and Resonant)		500				
Tee Joint Removal	95	100	100	125	125	125
SWER Reinsulation			120	120	120	120
<i>*Include additional rows if needed</i>						
All other projects or programmes - other reliability, safety and environment						
Other reliability, safety and environment expenditure	320	1,335	670	745	745	745
less Capital contributions funding other reliability, safety and environment						
Other reliability, safety and environment less capital contributions	320	1,335	670	745	745	745
11a(ix): Non-Network Assets						
Routine expenditure						
<i>Project or programme*</i>						
\$000 (in constant prices)						
Test Equipment	20	65	50	50	50	50
Plant and Tools	175	237	300	300	300	300
Vehicles	500	726	400	400	400	400
Land, Buildings and office equipment	535	85	200	200	200	200
IT Computers	575	368	400	400	400	400
<i>*Include additional rows if needed</i>						
All other projects or programmes - routine expenditure						
Routine expenditure	1,905	1,481	1,450	1,450	1,450	1,450
Atypical expenditure						
<i>Project or programme*</i>						
\$000 (in constant prices)						
Radio Equipment		480	480			
Office Building						
<i>*Include additional rows if needed</i>						
All other projects or programmes - atypical expenditure						
Atypical expenditure	-	480	480	-	-	-
Expenditure on non-network assets	1,905	1,961	1,930	1,450	1,450	1,450

Company Name **Marlborough Lines**
 AMP Planning Period **1 April 2016 – 31 March 2026**

SCHEDULE 11b: REPORT ON FORECAST OPERATIONAL EXPENDITURE

This schedule requires a breakdown of forecast operational expenditure for the disclosure year and a 10 year planning period. The forecasts should be consistent with the supporting information set out in the AMP. The forecast is to be expressed in both constant price and nominal dollar terms. EDBs must provide explanatory comment on the difference between constant price and nominal dollar operational expenditure forecasts in Schedule 14a (Mandatory Explanatory Notes). This information is not part of audited disclosure information.

sch ref		Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5	CY+6	CY+7	CY+8	CY+9	CY+10
		for year ended 31 Mar 16	31 Mar 17	31 Mar 18	31 Mar 19	31 Mar 20	31 Mar 21	31 Mar 22	31 Mar 23	31 Mar 24	31 Mar 25	31 Mar 26
9	Operational Expenditure Forecast	\$000 (in nominal dollars)										
10	Service interruptions and emergencies	775	783	791	798	806	815	823	831	839	848	856
11	Vegetation management	2,210	2,232	2,254	2,277	2,300	2,323	2,346	2,369	2,393	2,417	2,441
12	Routine and corrective maintenance and inspection	2,430	2,454	2,479	2,504	2,529	2,554	2,579	2,605	2,631	2,658	2,684
13	Asset replacement and renewal	560	566	571	577	583	589	594	600	606	612	619
14	Network Opex	5,975	6,035	6,095	6,156	6,218	6,280	6,343	6,406	6,470	6,535	6,600
15	System operations and network support	2,350	2,374	2,397	2,421	2,445	2,470	2,495	2,520	2,545	2,570	2,596
16	Business support	3,750	3,788	3,825	3,864	3,902	3,941	3,981	4,021	4,061	4,101	4,142
17	Non-network opex	6,100	6,161	6,223	6,285	6,348	6,411	6,475	6,540	6,605	6,671	6,738
18	Operational expenditure	12,075	12,196	12,318	12,441	12,565	12,691	12,818	12,946	13,075	13,206	13,338
22		\$000 (in constant prices)										
22	Service interruptions and emergencies	775	800	800	800	800	800	800	800	800	800	800
23	Vegetation management	2,210	2,200	2,200	2,200	2,200	2,200	2,200	2,200	2,200	2,200	2,200
24	Routine and corrective maintenance and inspection	2,430	2,400	2,400	2,400	2,400	2,400	2,400	2,400	2,400	2,400	2,400
25	Asset replacement and renewal	560	600	600	600	600	600	600	600	600	600	600
26	Network Opex	5,975	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000
27	System operations and network support	2,350	2,400	2,400	2,400	2,400	2,400	2,400	2,400	2,400	2,400	2,400
28	Business support	3,750	3,800	3,800	3,800	3,800	3,800	3,800	3,800	3,800	3,800	3,800
29	Non-network opex	6,100	6,200	6,200	6,200	6,200	6,200	6,200	6,200	6,200	6,200	6,200
30	Operational expenditure	12,075	12,200	12,200	12,200	12,200	12,200	12,200	12,200	12,200	12,200	12,200
31	Subcomponents of operational expenditure (where known)											
32	Energy efficiency and demand side management, reduction of energy losses											
34	Direct billing*											
35	Research and Development											
36	Insurance	250	250	250	250	250	250	250	250	250	250	250
37	* Direct billing expenditure by suppliers that direct bill the majority of their consumers											
41	Difference between nominal and real forecasts	\$000										
42	Service interruptions and emergencies	-	(17)	(9)	(2)	6	15	23	31	39	48	56
43	Vegetation management	-	32	54	77	100	123	146	169	193	217	241
44	Routine and corrective maintenance and inspection	-	54	79	104	129	154	179	205	231	258	284
45	Asset replacement and renewal	-	(34)	(29)	(23)	(17)	(11)	(6)	0	6	12	19
46	Network Opex	-	35	95	156	218	280	343	406	470	535	600
47	System operations and network support	-	(27)	(3)	21	45	70	95	120	145	170	196
48	Business support	-	(13)	25	64	102	141	181	221	261	301	342
49	Non-network opex	-	(39)	23	85	148	211	275	340	405	471	538
50	Operational expenditure	-	(4)	118	241	365	491	618	746	875	1,006	1,138

Company Name **Marlborough Lines**
 AMP Planning Period **1 April 2016 – 31 March 2026**

SCHEDULE 12a: REPORT ON ASSET CONDITION

This schedule requires a breakdown of asset condition by asset class as at the start of the forecast year. The data accuracy assessment relates to the percentage values disclosed in the asset condition columns. Also required is a forecast of the percentage of units to be replaced in the next 5 years. All information should be consistent with the information provided in the AMP and the expenditure on assets forecast in Schedule 11a. All units relating to cable and line assets, that are expressed in km, refer to circuit lengths.

sch ref		Asset condition at start of planning period (percentage of units by grade)										
	Voltage	Asset category	Asset class	Units	Grade 1	Grade 2	Grade 3	Grade 4	Grade unknown	Data accuracy (1-4)	% of asset forecast to be replaced in next 5 years	
7	All	Overhead Line	Concrete poles / steel structure	No.	0.20%	0.60%	55.40%	31.10%	12.70%	3	1.00%	
8	All	Overhead Line	Wood poles	No.	0.20%	2.70%	65.50%	22.70%	8.90%	3	8.00%	
	All	Overhead Line	Other pole types	No.	0.40%	3.60%	79.80%	11.80%	4.40%	2	8.00%	
13	HV	Subtransmission Line	Subtransmission OH up to 66kV conductor	km	1.10%	0.30%	41.70%	56.90%		3		
14	HV	Subtransmission Line	Subtransmission OH 110kV+ conductor	km						N/A		
15	HV	Subtransmission Cable	Subtransmission UG up to 66kV (XLPE)	km			92.20%	7.80%		3		
16	HV	Subtransmission Cable	Subtransmission UG up to 66kV (Oil pressurised)	km						N/A		
17	HV	Subtransmission Cable	Subtransmission UG up to 66kV (Gas pressurised)	km						N/A		
18	HV	Subtransmission Cable	Subtransmission UG up to 66kV (PILC)	km			100.00%			3		
19	HV	Subtransmission Cable	Subtransmission UG 110kV+ (XLPE)	km						N/A		
20	HV	Subtransmission Cable	Subtransmission UG 110kV+ (Oil pressurised)	km						N/A		
21	HV	Subtransmission Cable	Subtransmission UG 110kV+ (Gas Pressurised)	km						N/A		
22	HV	Subtransmission Cable	Subtransmission UG 110kV+ (PILC)	km						N/A		
23	HV	Subtransmission Cable	Subtransmission submarine cable	km						N/A		
24	HV	Zone substation Buildings	Zone substations up to 66kV	No.			44.00%	56.00%		4		
25	HV	Zone substation Buildings	Zone substations 110kV+	No.						N/A		
26	HV	Zone substation switchgear	22/33kV CB (Indoor)	No.			34.90%	65.10%		4		
27	HV	Zone substation switchgear	22/33kV CB (Outdoor)	No.			58.00%	42.00%		4		
28	HV	Zone substation switchgear	33kV Switch (Ground Mounted)	No.						N/A		
29	HV	Zone substation switchgear	33kV Switch (Pole Mounted)	No.			85.00%	15.00%		4		
30	HV	Zone substation switchgear	33kV RMU	No.			100.00%			4		
31	HV	Zone substation switchgear	50/66/110kV CB (Indoor)	No.						N/A		
32	HV	Zone substation switchgear	50/66/110kV CB (Outdoor)	No.						N/A		
33	HV	Zone substation switchgear	3.3/6.6/11/22kV CB (ground mounted)	No.			72.00%	28.00%		4		
34	HV	Zone substation switchgear	3.3/6.6/11/22kV CB (pole mounted)	No.			31.00%	69.00%		4		
35												

Company Name	Marlborough Lines
AMP Planning Period	1 April 2016 – 31 March 2026

SCHEDULE 12a: REPORT ON ASSET CONDITION

This schedule requires a breakdown of asset condition by asset class as at the start of the forecast year. The data accuracy assessment relates to the percentage values disclosed in the asset condition columns. Also required is a forecast of the percentage of units to be replaced in the next 5 years. All information should be consistent with the information provided in the AMP and the expenditure on assets forecast in Schedule 11a. All units relating to cable and line assets, that are expressed in km, refer to circuit lengths.

sch ref	Asset condition at start of planning period (percentage of units by grade)										
	Voltage	Asset category	Asset class	Units	Grade 1	Grade 2	Grade 3	Grade 4	Grade unknown	Data accuracy (1-4)	% of asset forecast to be replaced in next 5 years
36											
37											
38											
39	HV	Zone Substation Transformer	Zone Substation Transformers	No.			87.00%	13.00%		4	
40	HV	Distribution Line	Distribution OH Open Wire Conductor	km	0.10%	1.80%	66.00%	31.90%	0.20%	3	9.00%
41	HV	Distribution Line	Distribution OH Aerial Cable Conductor	km				100.00%		4	
42	HV	Distribution Line	SWER conductor	km	0.30%	4.70%	75.10%	19.80%	0.10%	3	
43	HV	Distribution Cable	Distribution UG XLPE or PVC	km			86.00%	14.00%		3	
44	HV	Distribution Cable	Distribution UG PILC	km			100.00%			3	
45	HV	Distribution Cable	Distribution Submarine Cable	km					N/A		
46	HV	Distribution switchgear	3.3/6.6/11/22kV CB (pole mounted) - reclosers and sectionalisers	No.			58.00%	42.00%		4	
47	HV	Distribution switchgear	3.3/6.6/11/22kV CB (Indoor)	No.			88.00%	12.00%		4	
48	HV	Distribution switchgear	3.3/6.6/11/22kV Switches and fuses (pole mounted)	No.			77.00%	23.00%		3	
49	HV	Distribution switchgear	3.3/6.6/11/22kV Switch (ground mounted) - except RMU	No.			100.00%			4	
50	HV	Distribution switchgear	3.3/6.6/11/22kV RMU	No.			75.00%	25.00%		4	
51	HV	Distribution Transformer	Pole Mounted Transformer	No.		0.80%	92.60%	6.60%		3	7.00%
52	HV	Distribution Transformer	Ground Mounted Transformer	No.			91.00%	9.00%		4	7.00%
53	HV	Distribution Transformer	Voltage regulators	No.			93.00%	7.00%		4	3.00%
54	HV	Distribution Substations	Ground Mounted Substation Housing	No.					N/A		
55	LV	LV Line	LV OH Conductor	km	0.20%	1.90%	58.30%	39.30%	0.30%	3	3.00%
56	LV	LV Cable	LV UG Cable	km			87.00%	13.00%		3	-
57	LV	LV Streetlighting	LV OH/UG Streetlight circuit	km			84.00%	16.00%		3	-
58	LV	Connections	OH/UG consumer service connections	No.	0.40%	3.50%	62.20%	33.90%		4	3.50%
59	All	Protection	Protection relays (electromechanical, solid state and numeric)	No.			64.00%	36.00%		4	4.00%
60	All	SCADA and communications	SCADA and communications equipment operating as a single system	Lot			90.00%	10.00%		3	
61	All	Capacitor Banks	Capacitors including controls	No.					N/A		
62	All	Load Control	Centralised plant	Lot			100.00%			4	
63	All	Load Control	Relays	No.					N/A		
64	All	Civils	Cable Tunnels	km					N/A		

Company Name

Marlborough Lines

AMP Planning Period

1 April 2016 – 31 March 2026

SCHEDULE 12b: REPORT ON FORECAST CAPACITY

This schedule requires a breakdown of current and forecast capacity and utilisation for each zone substation and current distribution transformer capacity. The data provided should be consistent with the information provided in the AMP. Information provided in this table should relate to the operation of the network in its normal steady state configuration.

sch ref

7 12b(i): System Growth - Zone Substations

8		Current Peak Load (MVA)	Installed Firm Capacity (MVA)	Security of Supply Classification (type)	Transfer Capacity (MVA)	Utilisation of Installed Firm Capacity %	Installed Firm Capacity +5 years (MVA)	Utilisation of Installed Firm Capacity + 5yrs %	Installed Firm Capacity Constraint +5 years (cause)	Explanation
9	<i>Existing Zone Substations</i>									
10	Leefield	1	5	n	1	25%	5	33.2%	No constraint within +5 years	Some load may be moved from Renwick
11	Linkwater	3	5	n	1	70%	5	69.6%	No constraint within +5 years	
12	Havelock	2	5	n-1	2	44%	5	44.1%	No constraint within +5 years	
13	Nelson St	15	17	n-1	8	90%	16.5	89.8%	No constraint within +5 years	
14	Picton	7	17	n-1	-	44%	16.5	44.1%	No constraint within +5 years	
15	Rai Valley	2	3	n-1	1	72%	3	71.8%	No constraint within +5 years	
16	Redwoodtown	10	17	n-1	8	60%	16.5	59.6%	No constraint within +5 years	
17	Renwick	10	10	n-1	5	99%	10	133.1%	Transformer	Open point may need moving to Mmove load to Leefield
18	Riverlands	10	10	n-1	8	100%	10	117.9%	Transformer	Bay/Waters
19	Seddon	8	10	n-1	1	100%	10	102.0%	Transformer	Open point may need moving to move load to Ward
20	Spring Creek	4	5	n-1	5	85%	5	114.7%	Transformer	Open point may need moving to move load to Springlands
21	Springlands	10	17	n-1	10	60%	16.5	60.0%	No constraint within +5 years	Some load may be moved from Spring Creek
22	Ward	2	2	n	1	79%	5	43.0%	No constraint within +5 years	Some load may be moved from Seddon
23	Waters	7	17	n-1	10	41%	16.5	40.9%	No constraint within +5 years	Some load to be moved from Riverlands
24	Woodbourne	9	10	n-1	5	86%	10	116.4%	No constraint within +5 years	
25	Cloudy Bay	4	17	n-1	5	22%	17	26.1%	No constraint within +5 years	Some load to be moved from Riverlands
26						-				
27						-				
28						-				
29						-				

¹ Extend forecast capacity table as necessary to disclose all capacity by each zone substation

Company Name **Marlborough Lines**
 AMP Planning Period **1 April 2016 – 31 March 2026**

SCHEDULE 12C: REPORT ON FORECAST NETWORK DEMAND

This schedule requires a forecast of new connections (by consumer type), peak demand and energy volumes for the disclosure year and a 5 year planning period. The forecasts should be consistent with the supporting information set out in the AMP as well as the assumptions used in developing the expenditure forecasts in Schedule 11a and Schedule 11b and the capacity and utilisation forecasts in Schedule 12b.

sch ref

12c(i): Consumer Connections

Number of ICPs connected in year by consumer type

	Number of connections					
	Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5
for year ended	31 Mar 16	31 Mar 17	31 Mar 18	31 Mar 19	31 Mar 20	31 Mar 21
<i>Consumer types defined by EDB*</i>						
Domestic	160	120	120	120	120	120
Small Commercial	12	10	10	10	10	10
Large Commercial/Industrial	3	1	1	1	1	1
Irrigation	1	1	1	1	1	1
Connections total	176	132	132	132	132	132

*include additional rows if needed

Distributed generation

Number of connections	70	100	120	200	200	200
Capacity of distributed generation installed in year (MVA)	0	0	0	1	1	1

12c(ii) System Demand

Maximum coincident system demand (MW)

	Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5
for year ended	31 Mar 16	31 Mar 17	31 Mar 18	31 Mar 19	31 Mar 20	31 Mar 21
GXP demand	69	69	69	69	69	69
plus Distributed generation output at HV and above	3	3	3	3	3	3
Maximum coincident system demand	72	72	72	72	72	72
less Net transfers to (from) other EDBs at HV and above	-	-	-	-	-	-
Demand on system for supply to consumers' connection points	72	72	72	72	72	72

Electricity volumes carried (GWh)

Electricity supplied from GXPs	383	385	385	385	385	385
less Electricity exports to GXPs	-	-	-	-	-	-
plus Electricity supplied from distributed generation	14	13	13	13	13	13
less Net electricity supplied to (from) other EDBs						
Electricity entering system for supply to ICPs	397	398	398	398	398	398
less Total energy delivered to ICPs						
Losses	397	398	398	398	398	398
Load factor	63%	63%	63%	63%	63%	63%
Loss ratio	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Company Name	Marlborough Lines
AMP Planning Period	1 April 2016 – 31 March 2026
Network / Sub-network Name	

SCHEDULE 12d: REPORT FORECAST INTERRUPTIONS AND DURATION

This schedule requires a forecast of SAIFI and SAIDI for disclosure and a 5 year planning period. The forecasts should be consistent with the supporting information set out in the AMP as well as the assumed impact of planned and unplanned SAIFI and SAIDI on the expenditures forecast provided in Schedule 11a and Schedule 11b.

sch ref		Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5
	for year ended	31 Mar 16	31 Mar 17	31 Mar 18	31 Mar 19	31 Mar 20	31 Mar 21
8							
9							
10	SAIDI						
11	Class B (planned interruptions on the network)	65.0	65.0	65.0	65.0	65.0	65.0
12	Class C (unplanned interruptions on the network)	65.0	80.0	80.0	80.0	80.0	80.0
13	SAIFI						
14	Class B (planned interruptions on the network)	0.20	0.20	0.20	0.20	0.20	0.20
15	Class C (unplanned interruptions on the network)	0.85	0.85	0.85	0.85	0.85	0.85

Company Name	Marlborough Lines
AMP Planning Period	1 April 2016 – 31 March 2026
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY

This schedule requires information on the EDB's self-assessment of the maturity of its asset management practices.

Question No.	Function	Question	Score	Evidence—Summary	User Guidance	Why	Who	Record/document Information
3	Asset management policy	To what extent has an asset management policy been documented, authorised and communicated?	2.5	The AMP contains an AM Policy at section 1.11.1 (Disclosure of interest - this policy was drafted by P.Caffyn). Inclusion of this Policy in the AMP will mean that it will have received Board approval as part of the AMP sign-off process. It is noted that the AM Policy and the AM Strategy include several of the elements noted in the EEA Guide (setting targets in response to stakeholder preferences, guides for key decisions, and key principles of good AM).	Andrew has suggested that the AM Policy and the AM Strategy could be published separately from the AMP.	Widely used AM practice standards require an organisation to document, authorise and communicate its asset management policy (eg, as required in PAS 55 para 4.2 i). A key pre-requisite of any robust policy is that the organisation's top management must be seen to endorse and fully support it. Also vital to the effective implementation of the policy, is to tell the appropriate people of its content and their obligations under it. Where an organisation outsources some of its asset-related activities, then these people and their organisations must equally be made aware of the policy's content. Also, there may be other stakeholders, such as regulatory authorities and shareholders who should be made aware of it.	Top management. The management team that has overall responsibility for asset management.	The organisation's asset management policy, its organisational strategic plan, documents indicating how the asset management policy was based upon the needs of the organisation and evidence of communication.
10	Asset management strategy	What has the organisation done to ensure that its asset management strategy is consistent with other appropriate organisational policies and strategies, and the needs of stakeholders?	2.5	The AMP contains an AM Strategy at sections 1.11.2 to 1.11.6 which expands on the AM Policy. This AM Strategy was deliberately written in conjunction with the AM Policy to ensure consistency. A review of this AM Strategy indicates that it is aligned to Marlborough Lines overall corporate direction.	Wayne said that this year different people will be writing different chapters of the AMP to ensure a wider range of views are captured.	In setting an organisation's asset management strategy, it is important that it is consistent with any other policies and strategies that the organisation has and has taken into account the requirements of relevant stakeholders. This question examines to what extent the asset management strategy is consistent with other organisational policies and strategies (eg, as required by PAS 55 para 4.3.1 b) and has taken account of stakeholder requirements as required by PAS 55 para 4.3.1 c). Generally, this will take into account the same policies, strategies and stakeholder requirements as covered in drafting the asset management policy but at a greater level of detail.	Top management. The organisation's strategic planning team. The management team that has overall responsibility for asset management.	The organisation's asset management strategy document and other related organisational policies and strategies. Other than the organisation's strategic plan, these could include those relating to health and safety, environmental, etc. Results of stakeholder consultation.
11	Asset management strategy	In what way does the organisation's asset management strategy take account of the lifecycle of the assets, asset types and asset systems over which the organisation has stewardship?	2.5	The AM Strategy at section 1.11.3 briefly mentions several asset attributes under the heading of "asset configuration". Section 6 of the AMP discusses asset lifecycle in more depth, and is based around asset types.	Andrew noted that assets have always been managed by asset class. Wayne's comment that the Long & Crawford oil switches would've been removed long ago if they were in Blenheim (but are remaining in service with a live operating ban) indicates that issues such as public safety risk and fault level are considered when	Good asset stewardship is the hallmark of an organisation compliant with widely used AM standards. A key component of this is the need to take account of the lifecycle of the assets, asset types and asset systems. (For example, this requirement is recognised in 4.3.1 d) of PAS 55). This question explores what an organisation has done to take lifecycle into account in its asset management strategy.	Top management. People in the organisation with expert knowledge of the assets, asset types, asset systems and their associated life-cycles. The management team that has overall responsibility for asset management. Those responsible for developing and adopting methods and processes used in asset management	The organisation's documented asset management strategy and supporting working documents.
26	Asset management plan(s)	How does the organisation establish and document its asset management plan(s) across the life cycle activities of its assets and asset systems?	2.5	The AMP firstly breaks down the network by asset class, and then secondly considers activities that are required as an assets' life progresses (principally through testing and inspections, minor maintenance and renewals).	Andrew noted that the AMP doesn't discuss decommissioning and disposal of assets as well as it could. Wayne's comment that the Long & Crawford oil switches would've been removed if they were in Blenheim shows evidence of further disaggregation of assets for AM purposes by consideration of	The asset management strategy need to be translated into practical plan(s) so that all parties know how the objectives will be achieved. The development of plan(s) will need to identify the specific tasks and activities required to optimize costs, risks and performance of the assets and/or asset system(s), when they are to be carried out and the resources required.	The management team with overall responsibility for the asset management system. Operations, maintenance and engineering managers.	The organisation's asset management plan(s).

Company Name
AMP Planning Period
Asset Management Standard Applied

Marlborough Lines
1 April 2016 – 31 March 2026

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

Question No.	Function	Question	Maturity Level 0	Maturity Level 1	Maturity Level 2	Maturity Level 3	Maturity Level 4
3	Asset management policy	To what extent has an asset management policy been documented, authorised and communicated?	The organisation does not have a documented asset management policy.	The organisation has an asset management policy, but it has not been authorised by top management, or it is not influencing the management of the assets.	The organisation has an asset management policy, which has been authorised by top management, but it has had limited circulation. It may be in use to influence development of strategy and planning but its effect is limited.	The asset management policy is authorised by top management, is widely and effectively communicated to all relevant employees and stakeholders, and used to make these persons aware of their asset related obligations.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
10	Asset management strategy	What has the organisation done to ensure that its asset management strategy is consistent with other appropriate organisational policies and strategies, and the needs of stakeholders?	The organisation has not considered the need to ensure that its asset management strategy is appropriately aligned with the organisation's other organisational policies and strategies or with stakeholder requirements. OR The organisation does not have an asset management strategy.	The need to align the asset management strategy with other organisational policies and strategies as well as stakeholder requirements is understood and work has started to identify the linkages or to incorporate them in the drafting of asset management strategy.	Some of the linkages between the long term asset management strategy and other organisational policies, strategies and stakeholder requirements are defined but the work is fairly well advanced but still incomplete.	All linkages are in place and evidence is available to demonstrate that, where appropriate, the organisation's asset management strategy is consistent with its other organisational policies and strategies. The organisation has also identified and considered the requirements of relevant stakeholders.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
11	Asset management strategy	In what way does the organisation's asset management strategy take account of the lifecycle of the assets, asset types and asset systems over which the organisation has stewardship?	The organisation has not considered the need to ensure that its asset management strategy is produced with due regard to the lifecycle of the assets, asset types or asset systems that it manages. OR The organisation does not have an asset management strategy.	The need is understood, and the organisation is drafting its asset management strategy to address the lifecycle of its assets, asset types and asset systems.	The long-term asset management strategy takes account of the lifecycle of some, but not all, of its assets, asset types and asset systems.	The asset management strategy takes account of the lifecycle of all of its assets, asset types and asset systems.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
26	Asset management plan(s)	How does the organisation establish and document its asset management plan(s) across the life cycle activities of its assets and asset systems?	The organisation does not have an identifiable asset management plan(s) covering asset systems and critical assets.	The organisation has asset management plan(s) but they are not aligned with the asset management strategy and objectives and do not take into consideration the full asset life cycle (including asset creation, acquisition, enhancement, utilisation, maintenance decommissioning and disposal).	The organisation is in the process of putting in place comprehensive, documented asset management plan(s) that cover all life cycle activities, clearly aligned to asset management objectives and the asset management strategy.	Asset management plan(s) are established, documented, implemented and maintained for asset systems and critical assets to achieve the asset management strategy and asset management objectives across all life cycle phases.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.

Company Name **Marlborough Lines**
 AMP Planning Period **1 April 2016 – 31 March 2026**
 Asset Management Standard Applied

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY

This schedule requires information on the EDB'S self-assessment of the maturity of its asset management practices.

Company Name **Marlborough Lines**
 AMP Planning Period **1 April 2016 – 31 March 2026**
 Asset Management Standard Applied

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

Question No.	Function	Question	Score	Evidence—Summary	User Guidance	Why	Who	Record/document Information
27	Asset management plan(s)	How has the organisation communicated its plan(s) to all relevant parties to a level of detail appropriate to the receiver's role in their delivery?	2.5	The AMP contains an AM Policy at section 1.11.1 (Disclosure of interest - this policy was drafted by P.Caffyn). Inclusion of this Policy in the AMP will mean that it will have received Board approval as part of the AMP sign-off process. It is noted that the AM Policy and the AM Strategy include several of the elements noted	Andrew has suggested that the AM Policy and the AM Strategy could be published separately from the AMP.	Plans will be ineffective unless they are communicated to all those, including contracted suppliers and those who undertake enabling function(s). The plan(s) need to be communicated in a way that is relevant to those who need to use them.	The management team with overall responsibility for the asset management system. Delivery functions and suppliers.	Distribution lists for plan(s). Documents derived from plan(s) which detail the receivers role in plan delivery. Evidence of communication.
29	Asset management plan(s)	How are designated responsibilities for delivery of asset plan actions documented?	2.5	The AMP contains an AM Strategy at sections 1.11.2 to 1.11.6 which expands on the AM Policy. This AM Strategy was deliberately written in conjunction with the AM Policy to ensure consistency. A review of this AM Strategy indicates that it is aligned to Marlborough Lines overall corporate direction.	Wayne said that this year different people will be writing different chapters of the AMP to ensure a wider range of views are captured.	The implementation of asset management plan(s) relies on (1) actions being clearly identified, (2) an owner allocated and (3) that owner having sufficient delegated responsibility and authority to carry out the work required. It also requires alignment of actions across the organisation. This question explores how well the plan(s) set out responsibility for delivery of asset plan actions.	The management team with overall responsibility for the asset management system. Operations, maintenance and engineering managers. If appropriate, the performance management team.	The organisation's asset management plan(s). Documentation defining roles and responsibilities of individuals and organisational departments.
31	Asset management plan(s)	What has the organisation done to ensure that appropriate arrangements are made available for the efficient and cost effective implementation of the plan(s)? (Note this is about resources and enabling support)	2.5	The AM Strategy at section 1.11.3 briefly mentions several asset attributes under the heading of "asset configuration". Section 6 of the AMP discusses asset lifecycle in more depth, and is based around asset types.	Andrew noted that assets have always been managed by asset class. Wayne's comment that the Long & Crawford oil switches would've been removed long ago if they were in Blenheim (but are remaining in service with a live operating ban) indicates that issues such as public safety risk and fault level are considered when making AM decisions.	It is essential that the plan(s) are realistic and can be implemented, which requires appropriate resources to be available and enabling mechanisms in place. This question explores how well this is achieved. The plan(s) not only need to consider the resources directly required and timescales, but also the enabling activities, including for example, training requirements, supply chain capability and procurement timescales.	The management team with overall responsibility for the asset management system. Operations, maintenance and engineering managers. If appropriate, the performance management team. Where appropriate the procurement team and service providers working on the organisation's asset-related activities.	The organisation's asset management plan(s). Documented processes and procedures for the delivery of the asset management plan.
33	Contingency planning	What plan(s) and procedure(s) does the organisation have for identifying and responding to incidents and emergency situations and ensuring continuity of critical asset management activities?	2.5	The AMP firstly breaks down the network by asset class, and then secondly considers activities that are required as an assets' life progresses (principally through testing and inspections, minor maintenance and renewals).	Andrew noted that the AMP doesn't discuss decommissioning and disposal of assets as well as it could. Wayne's comment that the Long & Crawford oil switches would've been removed if they were in Blenheim shows evidence of further disaggregation of assets for AM purposes by consideration of public safety risk and fault level.	Widely used AM practice standards require that an organisation has plan(s) to identify and respond to emergency situations. Emergency plan(s) should outline the actions to be taken to respond to specified emergency situations and ensure continuity of critical asset management activities including the communication to, and involvement of, external agencies. This question assesses if, and how well, these plan(s) triggered, implemented and resolved in the event of an incident. The plan(s) should be appropriate to the level of risk as determined by the organisation's risk assessment methodology. It is also a requirement that relevant personnel are competent and trained.	The manager with responsibility for developing emergency plan(s). The organisation's risk assessment team. People with designated duties within the plan(s) and procedure(s) for dealing with incidents and emergency situations.	The organisation's plan(s) and procedure(s) for dealing with emergencies. The organisation's risk assessments and risk registers.

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

Company Name	Marlborough Lines
AMP Planning Period	1 April 2016 – 31 March 2026
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

Company Name	Marlborough Lines
AMP Planning Period	1 April 2016 – 31 March 2026
Asset Management Standard Applied	

Question No.	Function	Question	Maturity Level 0	Maturity Level 1	Maturity Level 2	Maturity Level 3	Maturity Level 4
27	Asset management plan(s)	How has the organisation communicated its plan(s) to all relevant parties to a level of detail appropriate to the receiver's role in their delivery?	The organisation does not have plan(s) or their distribution is limited to the authors.	The plan(s) are communicated to some of those responsible for delivery of the plan(s). OR Communicated to those responsible for delivery is either irregular or ad-hoc.	The plan(s) are communicated to most of those responsible for delivery but there are weaknesses in identifying relevant parties resulting in incomplete or inappropriate communication. The organisation recognises improvement is needed as is working towards resolution.	The plan(s) are communicated to all relevant employees, stakeholders and contracted service providers to a level of detail appropriate to their participation or business interests in the delivery of the plan(s) and there is confirmation that they are being used effectively.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
29	Asset management plan(s)	How are designated responsibilities for delivery of asset plan actions documented?	The organisation has not documented responsibilities for delivery of asset plan actions.	Asset management plan(s) inconsistently document responsibilities for delivery of plan actions and activities and/or responsibilities and authorities for implementation inadequate and/or delegation level inadequate to ensure effective delivery and/or contain misalignments with organisational accountability.	Asset management plan(s) consistently document responsibilities for the delivery of actions but responsibility/authority levels are inappropriate/ inadequate, and/or there are misalignments within the organisation.	Asset management plan(s) consistently document responsibilities for the delivery actions and there is adequate detail to enable delivery of actions. Designated responsibility and authority for achievement of asset plan actions is appropriate.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
31	Asset management plan(s)	What has the organisation done to ensure that appropriate arrangements are made available for the efficient and cost effective implementation of the plan(s)? (Note this is about resources and enabling support)	The organisation has not considered the arrangements needed for the effective implementation of plan(s).	The organisation recognises the need to ensure appropriate arrangements are in place for implementation of asset management plan(s) and is in the process of determining an appropriate approach for achieving this.	The organisation has arrangements in place for the implementation of asset management plan(s) but the arrangements are not yet adequately efficient and/or effective. The organisation is working to resolve existing weaknesses.	The organisation's arrangements fully cover all the requirements for the efficient and cost effective implementation of asset management plan(s) and realistically address the resources and timescales required, and any changes needed to functional policies, standards, processes and the asset management information system.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
33	Contingency planning	What plan(s) and procedure(s) does the organisation have for identifying and responding to incidents and emergency situations and ensuring continuity of critical asset management activities?	The organisation has not considered the need to establish plan(s) and procedure(s) to identify and respond to incidents and emergency situations.	The organisation has some ad-hoc arrangements to deal with incidents and emergency situations, but these have been developed on a reactive basis in response to specific events that have occurred in the past.	Most credible incidents and emergency situations are identified. Either appropriate plan(s) and procedure(s) are incomplete for critical activities or they are inadequate. Training/ external alignment may be incomplete.	Appropriate emergency plan(s) and procedure(s) are in place to respond to credible incidents and manage continuity of critical asset management activities consistent with policies and asset management objectives. Training and external agency alignment is in place.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.

<p>SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY</p> <p>This schedule requires information on the EDB'S self-assessment of the maturity of its asset management practices.</p>	Company Name	Marlborough Lines
	AMP Planning Period	1 April 2016 – 31 March 2026
	Asset Management Standard Applied	

<p>SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)</p>	Company Name	Marlborough Lines
	AMP Planning Period	1 April 2016 – 31 March 2026
	Asset Management Standard Applied	

Question No.	Function	Question	Score	Evidence—Summary	User Guidance	Why	Who	Record/document Information
37	Structure, authority and responsibilities	What has the organisation done to appoint member(s) of its management team to be responsible for ensuring that the organisation's assets deliver the requirements of the asset management strategy, objectives and plan(s)?	3	Marlborough Lines has established a management structure (refer to POS07E) that is consistent with delivery of AM outcomes through engineering and contracting. This includes direct reports to the MD being accountable for outcomes such as engineering and works delivery. Marlborough Lines has also employed several graduate	Andrew confirmed that a schedule of Delegated Authorities is in place. Wayne confirmed that he is fully authorised to spend all budgeted funds without further reference to Ken.	In order to ensure that the organisation's assets and asset systems deliver the requirements of the asset management policy, strategy and objectives responsibilities need to be allocated to appropriate people who have the necessary authority to fulfil their responsibilities. (This question, relates to the organisation's assets eg, para b), s 4.4.1 of PAS 55, making it therefore distinct from the requirement contained in para a), s 4.4.1 of PAS 55).	Top management. People with management responsibility for the delivery of asset management policy, strategy, objectives and plan(s). People working on asset-related activities.	Evidence that managers with responsibility for the delivery of asset management policy, strategy, objectives and plan(s) have been appointed and have assumed their responsibilities. Evidence may include the organisation's documents relating to its asset management system, organisational charts, job descriptions of post-holders, annual targets/objectives and personal development plan(s) of post-holders as appropriate.
40	Structure, authority and responsibilities	What evidence can the organisation's top management provide to demonstrate that sufficient resources are available for asset management?	3	The bank statement shows a considerable cash balance which is available to fund works. Several graduate engineers have recently been recruited to ensure continuity of resources. It is also noted that 2 external contractors have shown keen interest in work that Contracting cannot complete by 31st March 2016	Bruce said that the AM activity is never cash constrained, and indeed has cash in the bank. This is through both prudent management of forecast pricing and through arranging financial facilities.	Optimal asset management requires top management to ensure sufficient resources are available. In this context the term 'resources' includes manpower, materials, funding and service provider support.	Top management. The management team that has overall responsibility for asset management. Risk management team. The organisation's managers involved in day-to-day supervision of asset-related activities, such as frontline managers, engineers, foremen and chargehands as appropriate.	Evidence demonstrating that asset management plan(s) and/or the process(es) for asset management plan implementation consider the provision of adequate resources in both the short and long term. Resources include funding, materials, equipment, services provided by third parties and personnel (internal and service providers) with appropriate skills competencies and knowledge.
42	Structure, authority and responsibilities	To what degree does the organisation's top management communicate the importance of meeting its asset management requirements?	3	The job descriptions communicate the importance of meeting AM targets eg. the MD's job description includes several high-level AM aspects including supply reliability, voltage, meeting demand growth and appropriate tariffs.	Jason said that AM targets and budgets are clearly signalled from Engineering. Wayne said that the Engineering staff are thoroughly familiar with the AM requirements.	Widely used AM practice standards require an organisation to communicate the importance of meeting its asset management requirements such that personnel fully understand, take ownership of, and are fully engaged in the delivery of the asset management requirements (eg, PAS 55 s 4.4.1 g).	Top management. The management team that has overall responsibility for asset management. People involved in the delivery of the asset management requirements.	Evidence of such activities as road shows, written bulletins, workshops, team talks and management walk-about would assist an organisation to demonstrate it is meeting this requirement of PAS 55.
45	Outsourcing of asset management activities	Where the organisation has outsourced some of its asset management activities, how has it ensured that appropriate controls are in place to ensure the compliant delivery of its organisational strategic plan, and its asset management policy and strategy?	3	Marlborough Lines tends to almost solely use its internal contracting division for works delivery. To ensure control of AM outcomes, Marlborough Lines has compiled a Network Design & Construction Standards Manual and a folder of Network Standard Drawings. Marlborough Lines has also developed a Procurement Hub that includes a systematic suite of contracts for purchasing goods, minor works, consultancy services etc.	Andrew said that Contracting has no authority to vary from Marlborough Lines design and construction standards, and can only do so on a case-by-case approval from the engineers. He did indicate that inspection and sign-off of completed works is an area that Marlborough Lines could do better at. There are also 2 zone substation transformer replacements that Contracting cannot perform prior to 31st March 2016, hence 2 external power line contractors have been approached. Both of these contractors are experienced in working for	Where an organisation chooses to outsource some of its asset management activities, the organisation must ensure that these outsourced process(es) are under appropriate control to ensure that all the requirements of widely used AM standards (eg, PAS 55) are in place, and the asset management policy, strategy objectives and plan(s) are delivered. This includes ensuring capabilities and resources across a time span aligned to life cycle management. The organisation must put arrangements in place to control the outsourced activities, whether it be to external providers or to other in-house departments. This question explores what the organisation does in this regard.	Top management. The management team that has overall responsibility for asset management. The manager(s) responsible for the monitoring and management of the outsourced activities. People involved with the procurement of outsourced activities. The people within the organisations that are performing the outsourced activities. The people impacted by the outsourced activity.	The organisation's arrangements that detail the compliance required of the outsourced activities. For example, this this could form part of a contract or service level agreement between the organisation and the suppliers of its outsourced activities. Evidence that the organisation has demonstrated to itself that it has assurance of compliance of outsourced activities.

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

Company Name	Marlborough Lines
AMP Planning Period	1 April 2016 – 31 March 2026
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

Company Name	Marlborough Lines
AMP Planning Period	1 April 2016 – 31 March 2026
Asset Management Standard Applied	

Question No.	Function	Question	Maturity Level 0	Maturity Level 1	Maturity Level 2	Maturity Level 3	Maturity Level 4
37	Structure, authority and responsibilities	What has the organisation done to appoint member(s) of its management team to be responsible for ensuring that the organisation's assets deliver the requirements of the asset management strategy, objectives and plan(s)?	Top management has not considered the need to appoint a person or persons to ensure that the organisation's assets deliver the requirements of the asset management strategy, objectives and plan(s).	Top management understands the need to appoint a person or persons to ensure that the organisation's assets deliver the requirements of the asset management strategy, objectives and plan(s).	Top management has appointed an appropriate person to ensure the assets deliver the requirements of the asset management strategy, objectives and plan(s) but their areas of responsibility are not fully defined and/or they have insufficient delegated authority to fully execute their responsibilities.	The appointed person or persons have full responsibility for ensuring that the organisation's assets deliver the requirements of the asset management strategy, objectives and plan(s). They have been given the necessary authority to achieve this.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
40	Structure, authority and responsibilities	What evidence can the organisation's top management provide to demonstrate that sufficient resources are available for asset management?	The organisation's top management has not considered the resources required to deliver asset management.	The organisation's top management understands the need for sufficient resources but there are no effective mechanisms in place to ensure this is the case.	A process exists for determining what resources are required for its asset management activities and in most cases these are available but in some instances resources remain insufficient.	An effective process exists for determining the resources needed for asset management and sufficient resources are available. It can be demonstrated that resources are matched to asset management requirements.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
42	Structure, authority and responsibilities	To what degree does the organisation's top management communicate the importance of meeting its asset management requirements?	The organisation's top management has not considered the need to communicate the importance of meeting asset management requirements.	The organisation's top management understands the need to communicate the importance of meeting its asset management requirements but does not do so.	Top management communicates the importance of meeting its asset management requirements but only to parts of the organisation.	Top management communicates the importance of meeting its asset management requirements to all relevant parts of the organisation.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
45	Outsourcing of asset management activities	Where the organisation has outsourced some of its asset management activities, how has it ensured that appropriate controls are in place to ensure the compliant delivery of its organisational strategic plan, and its asset management policy and strategy?	The organisation has not considered the need to put controls in place.	The organisation controls its outsourced activities on an ad-hoc basis, with little regard for ensuring for the compliant delivery of the organisational strategic plan and/or its asset management policy and strategy.	Controls systematically considered but currently only provide for the compliant delivery of some, but not all, aspects of the organisational strategic plan and/or its asset management policy and strategy. Gaps exist.	Evidence exists to demonstrate that outsourced activities are appropriately controlled to provide for the compliant delivery of the organisational strategic plan, asset management policy and strategy, and that these controls are integrated into the asset management system.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY This schedule requires information on the EDB'S self-assessment of the maturity of its asset management practices .	<i>Company Name</i>	Marlborough Lines
	<i>AMP Planning Period</i>	1 April 2016 – 31 March 2026
	<i>Asset Management Standard Applied</i>	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)	<i>Company Name</i>	Marlborough Lines
	<i>AMP Planning Period</i>	1 April 2016 – 31 March 2026
	<i>Asset Management Standard Applied</i>	

Question No.	Function	Question	Score	Evidence—Summary	User Guidance	Why	Who	Record/document information
48	Training, awareness and competence	How does the organisation develop plan(s) for the human resources required to undertake asset management activities - including the development and delivery of asset management strategy, process(es), objectives and plan(s)?	2.5	Marlborough Lines has recruited several graduate engineers to ensure continuity of engineering competencies. Several external contractors are asked to tender for work to ensure that AM plans are fully completed.	Jason said that Contracting tends to multi-skill, with all new trainee linemen being trained in faults and cable joining. This is to ensure that staff competencies match varying workloads. There is definitely an eye to the future with aging staff and competency requirements. Wayne commented that it is very rare for work to not get done because of insufficient competencies or staff numbers.	There is a need for an organisation to demonstrate that it has considered what resources are required to develop and implement its asset management system. There is also a need for the organisation to demonstrate that it has assessed what development plan(s) are required to provide its human resources with the skills and competencies to develop and implement its asset management systems. The timescales over which the plan(s) are relevant should be commensurate with the planning horizons within the asset management strategy considers e.g. if the asset management strategy considers 5, 10 and 15 year time scales then the human resources development plan(s) should align with these. Resources include both 'in house' and external resources who undertake asset management activities.	Senior management responsible for agreement of plan(s). Managers responsible for developing asset management strategy and plan(s). Managers with responsibility for development and recruitment of staff (including HR functions). Staff responsible for training. Procurement officers. Contracted service providers.	Evidence of analysis of future work load plan(s) in terms of human resources. Document(s) containing analysis of the organisation's own direct resources and contractors resource capability over suitable timescales. Evidence, such as minutes of meetings, that suitable management forums are monitoring human resource development plan(s). Training plan(s), personal development plan(s), contract and service level agreements.
49	Training, awareness and competence	How does the organisation identify competency requirements and then plan, provide and record the training necessary to achieve the competencies?	3	Marlborough Lines has a structured training and competency framework as part of its ISO 9001 certification. The competency requirements for each role (person) appear to have been identified by analysing the main tasks of each role.	Ben commented that Marlborough Lines offered him a scholarship to study for a B.Eng at Canterbury and then to come back to Blenheim.	Widely used AM standards require that organisations to undertake a systematic identification of the asset management awareness and competencies required at each level and function within the organisation. Once identified the training required to provide the necessary competencies should be planned for delivery in a timely and systematic way. Any training provided must be recorded and maintained in a suitable format. Where an organisation has contracted service providers in place then it should have a means to demonstrate that this requirement is being met for their employees. (eg, PAS 55 refers to frameworks suitable for identifying competency requirements).	Senior management responsible for agreement of plan(s). Managers responsible for developing asset management strategy and plan(s). Managers with responsibility for development and recruitment of staff (including HR functions). Staff responsible for training. Procurement officers. Contracted service providers.	Evidence of an established and applied competency requirements assessment process and plan(s) in place to deliver the required training. Evidence that the training programme is part of a wider, co-ordinated asset management activities training and competency programme. Evidence that training activities are recorded and that records are readily available (for both direct and contracted service provider staff) e.g. via organisation wide information system or local records database.

Company Name	Marlborough Lines
AMP Planning Period	1 April 2016 – 31 March 2026
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY

This schedule requires information on the EDB'S self-assessment of the maturity of its asset management practices.

50	Training, awareness and competence	How does the organization ensure that persons under its direct control undertaking asset management related activities have an appropriate level of competence in terms of education, training or experience?	3	Marlborough Lines has a structured training and competency framework as part of its ISO 9001 certification. This includes competency models for all staff that includes review dates. Field staff safety requirements and training are recorded in a comprehensive register.	Wayne said that there is a comprehensive competency register for all field staff.	A critical success factor for the effective development and implementation of an asset management system is the competence of persons undertaking these activities. organisations should have effective means in place for ensuring the competence of employees to carry out their designated asset management function(s). Where an organisation has contracted service providers undertaking elements of its asset management system then the organisation shall assure itself that the outsourced service provider also has suitable arrangements in place to manage the competencies of its employees. The organisation should ensure that the individual and corporate competencies it requires are in place and actively monitor, develop and maintain an appropriate balance of these competencies.	Managers, supervisors, persons responsible for developing training programmes. Staff responsible for procurement and service agreements. HR staff and those responsible for recruitment.	Evidence of a competency assessment framework that aligns with established frameworks such as the asset management Competencies Requirements Framework (Version 2.0); National Occupational Standards for Management and Leadership; UK Standard for Professional Engineering Competence, Engineering Council, 2005.
----	------------------------------------	---	---	--	---	--	--	--

Company Name AMP Planning Period Asset Management Standard Applied	Marlborough Lines
	1 April 2016 – 31 March 2026
SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)	

Company Name AMP Planning Period Asset Management Standard Applied	Marlborough Lines
	1 April 2016 – 31 March 2026
SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)	

Question No.	Function	Question	Maturity Level 0	Maturity Level 1	Maturity Level 2	Maturity Level 3	Maturity Level 4
48	Training, awareness and competence	How does the organisation develop plan(s) for the human resources required to undertake asset management activities - including the development and delivery of asset management strategy, process(es), objectives and plan(s)?	The organisation has not recognised the need for assessing human resources requirements to develop and implement its asset management system.	The organisation has recognised the need to assess its human resources requirements and to develop a plan(s). There is limited recognition of the need to align these with the development and implementation of its asset management system.	The organisation has developed a strategic approach to aligning competencies and human resources to the asset management system including the asset management plan but the work is incomplete or has not been consistently implemented.	The organisation can demonstrate that plan(s) are in place and effective in matching competencies and capabilities to the asset management system including the plan for both internal and contracted activities. Plans are reviewed integral to asset management system process(es).	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
49	Training, awareness and competence	How does the organisation identify competency requirements and then plan, provide and record the training necessary to achieve the competencies?	The organisation does not have any means in place to identify competency requirements.	The organisation has recognised the need to identify competency requirements and then plan, provide and record the training necessary to achieve the competencies.	The organisation is the process of identifying competency requirements aligned to the asset management plan(s) and then plan, provide and record appropriate training. It is incomplete or inconsistently applied.	Competency requirements are in place and aligned with asset management plan(s). Plans are in place and effective in providing the training necessary to achieve the competencies. A structured means of recording the competencies achieved is in place.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.

Company Name	Marlborough Lines
AMP Planning Period	1 April 2016 – 31 March 2026
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

50	Training, awareness and competence	How does the organization ensure that persons under its direct control undertaking asset management related activities have an appropriate level of competence in terms of education, training or experience?	The organization has not recognised the need to assess the competence of person(s) undertaking asset management related activities.	Competency of staff undertaking asset management related activities is not managed or assessed in a structured way, other than formal requirements for legal compliance and safety management.	The organization is in the process of putting in place a means for assessing the competence of person(s) involved in asset management activities including contractors. There are gaps and inconsistencies.	Competency requirements are identified and assessed for all persons carrying out asset management related activities - internal and contracted. Requirements are reviewed and staff reassessed at appropriate intervals aligned to asset management requirements.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
----	------------------------------------	---	---	--	---	---	---

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY This schedule requires information on the EDB'S self-assessment of the maturity of its asset management practices.	Company Name	Marlborough Lines
	AMP Planning Period	1 April 2016 – 31 March 2026
	Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)	Company Name	Marlborough Lines
	AMP Planning Period	1 April 2016 – 31 March 2026
	Asset Management Standard Applied	

Question No.	Function	Question	Score	Evidence—Summary	User Guidance	Why	Who	Record/document Information
53	Communication, participation and consultation	How does the organisation ensure that pertinent asset management information is effectively communicated to and from employees and other stakeholders, including contracted service providers?	3	The AMP and capital budget are given to Marlborough Lines Contracting as the primary communication tool. The Network Design & Construction Standards and the Network Standard Drawings are also provided to contractors to ensure conformity of works delivery. Ken reports to the Board on key AM outcomes including supply reliability, costs and works delivery.	Amanda described how the "Project One Road" IS project aims to make information more accessible to all staff. Hamish commented that him and Jason attend Marlborough Roads meetings to ensure that excavations are coordinated.	Widely used AM practice standards require that pertinent asset management information is effectively communicated to and from employees and other stakeholders including contracted service providers. Pertinent information refers to information required in order to effectively and efficiently comply with and deliver asset management strategy, plan(s) and objectives. This will include for example the communication of the asset management policy, asset performance information, and planning information as appropriate to contractors.	Top management and senior management representative(s), employee's representative(s), employee's trade union representative(s); contracted service provider management and employee representative(s); representative(s) from the organisation's Health, Safety and Environmental team. Key stakeholder representative(s).	Asset management policy statement prominently displayed on notice boards, intranet and internet; use of organisation's website for displaying asset performance data; evidence of formal briefings to employees, stakeholders and contracted service providers; evidence of inclusion of asset management issues in team meetings and contracted service provider contract meetings; newsletters, etc.
59	Asset Management System documentation	What documentation has the organisation established to describe the main elements of its asset management system and interactions between them?	3	A high-level summary of the AM IS is included in the AMP at section 1.12. The "Project One Road" presentation shows the high-level interaction of various AM IS's including EAM and Milsoft.	Amanda confirmed that migration from the Current State (BASIX, WASP etc) in the "Project One Road" presentation to the Future State (EAM, Milsoft) has now occurred.	Widely used AM practice standards require an organisation maintain up to date documentation that ensures that its asset management systems (ie, the systems the organisation has in place to meet the standards) can be understood, communicated and operated. (eg, s 4.5 of PAS 55 requires the maintenance of up to date documentation of the asset management system requirements specified throughout s 4 of PAS 55).	The management team that has overall responsibility for asset management. Managers engaged in asset management activities.	The documented information describing the main elements of the asset management system (process(es) and their interaction.
62	Information management	What has the organisation done to determine what its asset management information system(s) should contain in order to support its asset management system?	3	The "Project One Road" report identified several shortcomings of the former WASP AMIS including an inability to trend asset condition data, and to alter asset configurations.	Ben said that although much of the data collected is a continuation of legacy data capture practices, data requirements have been re-assessed eg. removing checks on redundant assets, adding new inspection criteria as new issues emerge. Ben quoted a few examples of check sheets being amended as it became apparent that vegetation was shorting out the substation fences and that warning signs were fading.	Effective asset management requires appropriate information to be available. Widely used AM standards therefore require the organisation to identify the asset management information it requires in order to support its asset management system. Some of the information required may be held by suppliers. The maintenance and development of asset management information systems is a poorly understood specialist activity that is akin to IT management but different from IT management. This group of questions provides some indications as to whether the capability is available and applied. Note: To be effective, an asset information management system requires the mobilisation of technology, people and process(es) that create, secure, make available and destroy the information required to support the asset management system.	The organisation's strategic planning team. The management team that has overall responsibility for asset management. Information management team. Operations, maintenance and engineering managers	Details of the process the organisation has employed to determine what its asset information system should contain in order to support its asset management system. Evidence that this has been effectively implemented.
63	Information management	How does the organisation maintain its asset management information system(s) and ensure that the data held within it (them) is of the requisite quality and accuracy and is consistent?	3	The AM IS's have been developed as part of "Project One Road" which is a strategy to remove legacy IS's such as BASIX and WASP that have limited functionality and declining vendor support.	Ben said that a key role of the GIS technician is to improve data quality. Marlborough Lines notes that this is an area that it needs to improve. Amanda said that data quality, accuracy and consistency is managed by individual user departments, and a large part of the high accuracy of GIS	The response to the questions is progressive. A higher scale cannot be awarded without achieving the requirements of the lower scale. This question explores how the organisation ensures that information management meets widely used AM practice requirements (eg, s 4.4.6 (a), (c) and (d) of PAS 55).	The management team that has overall responsibility for asset management. Users of the organisational information systems.	The asset management information system, together with the policies, procedure(s), improvement initiatives and audits regarding information controls.

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)	Company Name	Marlborough Lines
	AMP Planning Period	1 April 2016 – 31 March 2026
	Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)	Company Name	Marlborough Lines
	AMP Planning Period	1 April 2016 – 31 March 2026
	Asset Management Standard Applied	

Question No.	Function	Question	Maturity Level 0	Maturity Level 1	Maturity Level 2	Maturity Level 3	Maturity Level 4
53	Communication, participation and consultation	How does the organisation ensure that pertinent asset management information is effectively communicated to and from employees and other stakeholders, including contracted service providers?	The organisation has not recognised the need to formally communicate any asset management information.	There is evidence that the pertinent asset management information to be shared along with those to share it with is being determined.	The organisation has determined pertinent information and relevant parties. Some effective two way communication is in place but as yet not all relevant parties are clear on their roles and responsibilities with respect to asset management information.	Two way communication is in place between all relevant parties, ensuring that information is effectively communicated to match the requirements of asset management strategy, plan(s) and process(es). Pertinent asset information requirements are regularly reviewed.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
59	Asset Management System documentation	What documentation has the organisation established to describe the main elements of its asset management system and interactions between them?	The organisation has not established documentation that describes the main elements of the asset management system.	The organisation is aware of the need to put documentation in place and is in the process of determining how to document the main elements of its asset management system.	The organisation in the process of documenting its asset management system and has documentation in place that describes some, but not all, of the main elements of its asset management system and their interaction.	The organisation has established documentation that comprehensively describes all the main elements of its asset management system and the interactions between them. The documentation is kept up to date.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
62	Information management	What has the organisation done to determine what its asset management information system(s) should contain in order to support its asset management system?	The organisation has not considered what asset management information is required.	The organisation is aware of the need to determine in a structured manner what its asset information system should contain in order to support its asset management system and is in the process of deciding how to do this.	The organisation has developed a structured process to determine what its asset information system should contain in order to support its asset management system and has commenced implementation of the process.	The organisation has determined what its asset information system should contain in order to support its asset management system. The requirements relate to the whole life cycle and cover information originating from both internal and external sources.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
63	Information management	How does the organisation maintain its asset management information system(s) and ensure that the data held within it (them) is of the requisite quality and accuracy and is consistent?	There are no formal controls in place or controls are extremely limited in scope and/or effectiveness.	The organisation is aware of the need for effective controls and is in the process of developing an appropriate control process(es).	The organisation has developed a controls that will ensure the data held is of the requisite quality and accuracy and is consistent and is in the process of implementing them.	The organisation has effective controls in place that ensure the data held is of the requisite quality and accuracy and is consistent. The controls are regularly reviewed and improved where necessary.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.

<p>SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY</p> <p>This schedule requires information on the EDB'S self-assessment of the maturity of its asset management practices.</p>	Company Name	Marlborough Lines
	AMP Planning Period	1 April 2016 – 31 March 2026
	Asset Management Standard Applied	

<p>SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)</p>	Company Name	Marlborough Lines
	AMP Planning Period	1 April 2016 – 31 March 2026
	Asset Management Standard Applied	

Question No.	Function	Question	Score	Evidence—Summary	User Guidance	Why	Who	Record/document information
64	Information management	How has the organisation's ensured its asset management information system is relevant to its needs?	3	"Project One Road" has included process mapping of all major activities. The initial "Project One Road" report includes a statement of the limitations of the (former) WASP system and a statement of desired future position such as better integration.	Andrew commented that fields have been added and removed. The principle that "no data is better than bad data" has been adopted.	Widely used AM standards need not be prescriptive about the form of the asset management information system, but simply require that the asset management information system is appropriate to the organisations needs, can be effectively used and can supply information which is consistent and of the requisite quality and accuracy.	The organisation's strategic planning team. The management team that has overall responsibility for asset management. Information management team. Users of the organisational information systems.	The documented process the organisation employs to ensure its asset management information system aligns with its asset management requirements. Minutes of information systems review meetings involving users.
69	Risk management process(es)	How has the organisation documented process(es) and/or procedure(s) for the identification and assessment of asset and asset management related risks throughout the asset life cycle?	3	Section 6 of the AMP summarises how the asset lifecycle is managed ... drivers, assumptions and policies. This section also notes the range of condition monitoring tests that are performed on an asset class basis. The ISO 9001 system includes several policies dealing with network asset condition assessment, inspection & testing, and control of faulty poles. The PSMS includes a comprehensive risk assessment process. Evidence that	Andrew commented that the maintenance standard (under revision) breaks the network down by asset class and then considers the various risks associated with each asset class.	Risk management is an important foundation for proactive asset management. Its overall purpose is to understand the cause, effect and likelihood of adverse events occurring, to optimally manage such risks to an acceptable level, and to provide an audit trail for the management of risks. Widely used standards require the organisation to have process(es) and/or procedure(s) in place that set out how the organisation identifies and assesses asset and asset management related risks. The risks have to be considered across the four phases of the asset lifecycle (eg. para 4.3.3 of PAS 55).	The top management team in conjunction with the organisation's senior risk management representatives. There may also be input from the organisation's Safety, Health and Environment team. Staff who carry out risk identification and assessment.	The organisation's risk management framework and/or evidence of specific process(es) and/or procedure(s) that deal with risk control mechanisms. Evidence that the process(es) and/or procedure(s) are implemented across the business and maintained. Evidence of agendas and minutes from risk management meetings. Evidence of feedback in to process(es) and/or procedure(s) as a result of incident investigation(s). Risk registers and assessments.
79	Use and maintenance of asset risk information	How does the organisation ensure that the results of risk assessments provide input into the identification of adequate resources and training and competency needs?	3	Memo from engineering management establishing a live operating ban on all Long & Crawford oil switches in response to an accident in Australia was examined. This memo included identifying all remaining L&C switches and advising Contracting of the live operating ban.	Jason said that field services risks (eg. operation and construction) extensively drive safety training and competency. Ben quoted the example of changes to the operating procedures for Long & Crawford oil switches as a result of an EEA bulletin.	Widely used AM standards require that the output from risk assessments are considered and that adequate resource (including staff) and training is identified to match the requirements. It is a further requirement that the effects of the control measures are considered, as there may be implications in resources and training required to achieve other objectives.	Staff responsible for risk assessment and those responsible for developing and approving resource and training plan(s). There may also be input from the organisation's Safety, Health and Environment team.	The organisations risk management framework. The organisation's resourcing plan(s) and training and competency plan(s). The organisation should be able to demonstrate appropriate linkages between the content of resource plan(s) and training and competency plan(s) to the risk assessments and risk control measures that have been developed.
82	Legal and other requirements	What procedure does the organisation have to identify and provide access to its legal, regulatory, statutory and other asset management requirements, and how is requirements incorporated into the asset management system?	3	A quarterly legal compliance report covering the last quarter of 2015 from Brian to Geoff was examined, and it was noted that the relevant requirements of environmental, safety training, OSH and SMEI legislation were being complied with. The Legislative Compliance & Risk Management report to the Board for August 2015 was examined.	Geoff said that many bulletins from various statutory bodies (including the Audit Office), industry bodies, lawyers and consultants are received which advise on legal and regulatory changes. The CFO compiles significant matters into a quarterly report for the Board.	In order for an organisation to comply with its legal, regulatory, statutory and other asset management requirements, the organisation first needs to ensure that it knows what they are (eg. PAS 55 specifies this in s 4.4.8). It is necessary to have systematic and auditable mechanisms in place to identify new and changing requirements. Widely used AM standards also require that requirements are incorporated into the asset management system (e.g. procedure(s) and process(es))	Top management. The organisations regulatory team. The organisation's legal team or advisors. The management team with overall responsibility for the asset management system. The organisation's health and safety team or advisors. The organisation's policy making team.	The organisational processes and procedures for ensuring information of this type is identified, made accessible to those requiring the information and is incorporated into asset management strategy and objectives

<p style="text-align: right;">Company Name AMP Planning Period Asset Management Standard Applied</p> <p style="text-align: center;">SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)</p>							
<p>Company Name AMP Planning Period Asset Management Standard Applied</p> <p style="text-align: center;">SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)</p>							
Question No.	Function	Question	Maturity Level 0	Maturity Level 1	Maturity Level 2	Maturity Level 3	Maturity Level 4
64	Information management	How has the organisation's ensured its asset management information system is relevant to its needs?	The organisation has not considered the need to determine the relevance of its management information system. At present there are major gaps between what the information system provides and the organisations needs.	The organisation understands the need to ensure its asset management information system is relevant to its needs and is determining an appropriate means by which it will achieve this. At present there are significant gaps between what the information system provides and the organisations needs.	The organisation has developed and is implementing a process to ensure its asset management information system is relevant to its needs. Gaps between what the information system provides and the organisations needs have been identified and action is being taken to close them.	The organisation's asset management information system aligns with its asset management requirements. Users can confirm that it is relevant to their needs.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
69	Risk management process(es)	How has the organisation documented process(es) and/or procedure(s) for the identification and assessment of asset and asset management related risks throughout the asset life cycle?	The organisation has not considered the need to document process(es) and/or procedure(s) for the identification and assessment of asset and asset management related risks throughout the asset life cycle.	The organisation is aware of the need to document the management of asset related risk across the asset lifecycle. The organisation has plan(s) to formally document all relevant process(es) and procedure(s) or has already commenced this activity.	The organisation is in the process of documenting the identification and assessment of asset related risk across the asset lifecycle but it is incomplete or there are inconsistencies between approaches and a lack of integration.	Identification and assessment of asset related risk across the asset lifecycle is fully documented. The organisation can demonstrate that appropriate documented mechanisms are integrated across life cycle phases and are being consistently applied.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
79	Use and maintenance of asset risk information	How does the organisation ensure that the results of risk assessments provide input into the identification of adequate resources and training and competency needs?	The organisation has not considered the need to conduct risk assessments.	The organisation is aware of the need to consider the results of risk assessments and effects of risk control measures to provide input into reviews of resources, training and competency needs. Current input is typically ad-hoc and reactive.	The organisation is in the process ensuring that outputs of risk assessment are included in developing requirements for resources and training. The implementation is incomplete and there are gaps and inconsistencies.	Outputs from risk assessments are consistently and systematically used as inputs to develop resources, training and competency requirements. Examples and evidence is available.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
82	Legal and other requirements	What procedure does the organisation have to identify and provide access to its legal, regulatory, statutory and other asset management requirements, and how is requirements incorporated into the asset management system?	The organisation has not considered the need to identify its legal, regulatory, statutory and other asset management requirements.	The organisation identifies some its legal, regulatory, statutory and other asset management requirements, but this is done in an ad-hoc manner in the absence of a procedure.	The organisation has procedure(s) to identify its legal, regulatory, statutory and other asset management requirements, but the information is not kept up to date, inadequate or inconsistently managed.	Evidence exists to demonstrate that the organisation's legal, regulatory, statutory and other asset management requirements are identified and kept up to date. Systematic mechanisms for identifying relevant legal and statutory requirements.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.

Company Name **Marlborough Lines**
 AMP Planning Period **1 April 2016 – 31 March 2026**
 Asset Management Standard Applied

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY

This schedule requires information on the EDB'S self-assessment of the maturity of its asset management practices.

Company Name **Marlborough Lines**
 AMP Planning Period **1 April 2016 – 31 March 2026**
 Asset Management Standard Applied

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

Question No.	Function	Question	Score	Evidence—Summary	User Guidance	Why	Who	Record/document Information
88	Life Cycle Activities	How does the organisation establish implement and maintain process(es) for the implementation of its asset management plan(s) and control of activities across the creation, acquisition or enhancement of assets. This includes design, modification, procurement, construction and commissioning activities?	3	The principal control mechanisms for managing asset lifecycle safety, integrity and quality are the Network Standard Drawings, the Network Design & Construction Standards, the Materials Policy (section 1.11.5 of the AMP), and the Procurement Policy.	Jason concurred that the Network Design & Construction Standard Drawings provide a high level of control that managed build quality and operating risk. Any variations must be approved on a case-by-case basis by Engineering.	Life cycle activities are about the implementation of asset management plan(s) i.e. they are the "doing" phase. They need to be done effectively and well in order for asset management to have any practical meaning. As a consequence, widely used standards (eg, PAS 55 s 4.5.1) require organisations to have in place appropriate process(es) and procedure(s) for the implementation of asset management plan(s) and control of lifecycle activities. This question explores those aspects relevant to asset creation.	Asset managers, design staff, construction staff and project managers from other impacted areas of the business, e.g. Procurement	Documented process(es) and procedure(s) which are relevant to demonstrating the effective management and control of life cycle activities during asset creation, acquisition, enhancement including design, modification, procurement, construction and commissioning.
91	Life Cycle Activities	How does the organisation ensure that process(es) and/or procedure(s) for the implementation of asset management plan(s) and control of activities during maintenance (and inspection) of assets are sufficient to ensure activities are carried out under specified conditions, are consistent with asset management strategy and control cost, risk and performance?	2.5	Marlborough Lines design & construction standards embody many years of collective experience about what works and what doesn't. This is supplemented by revisions to include increasing safety obligations such as the PSMS. There are also purchasing policies, material standards, and contractual requirements to reduce the risk of variance from required standards of safety, cost, risk and alignment to strategy. The	Wayne commented that project close-out and closing the loop with improvements could be improved. Wayne commented that various other makes of equipment that are considered unsafe are also being removed.	Having documented process(es) which ensure the asset management plan(s) are implemented in accordance with any specified conditions, in a manner consistent with the asset management policy, strategy and objectives and in such a way that cost, risk and asset system performance are appropriately controlled is critical. They are an essential part of turning intention into action (eg, as required by PAS 55 s 4.5.1).	Asset managers, operations managers, maintenance managers and project managers from other impacted areas of the business	Documented procedure for review. Documented procedure for audit of process delivery. Records of previous audits, improvement actions and documented confirmation that actions have been carried out.
95	Performance and condition monitoring	How does the organisation measure the performance and condition of its assets?	3	Marlborough Lines measures the performance and condition of its assets in a number of ways that correspond to increasing timeframes. In the immediate term, network performance is measured by the number and duration of faults that cause customer supply interruptions. On a short-to-medium term basis network performance is measured in terms of component integrity eg. oil acidity, perishing of gaskets etc. On the long-term asset performance can be measured by capacity	Brian concurred that this is how it occurs in practice. Brian also described how MilsSoft can be used to indicate where volt drop is occurring	Widely used AM standards require that organisations establish implement and maintain procedure(s) to monitor and measure the performance and/or condition of assets and asset systems. They further set out requirements in some detail for reactive and proactive monitoring, and leading/lagging performance indicators together with the monitoring or results to provide input to corrective actions and continual improvement. There is an expectation that performance and condition monitoring will provide input to improving asset management strategy, objectives and plan(s).	A broad cross-section of the people involved in the organisation's asset-related activities from data input to decision-makers, i.e. an end-to-end assessment. This should include contactors and other relevant third parties as appropriate.	Functional policy and/or strategy documents for performance or condition monitoring and measurement. The organisation's performance monitoring frameworks, balanced scorecards etc. Evidence of the reviews of any appropriate performance indicators and the action lists resulting from these reviews. Reports and trend analysis using performance and condition information. Evidence of the use of performance and condition information shaping improvements and supporting asset management strategy, objectives and plan(s).
99	Investigation of asset-related failures, incidents and nonconformities	How does the organisation ensure responsibility and the authority for the handling, investigation and mitigation of asset-related failures, incidents and emergency situations and non conformances is clear, unambiguous, understood and communicated?	3	A key aspect of mitigating asset failures is the extensive use of design and construction standards to minimise the risk of assets failing in the first place. The Emergency Preparedness Plan defines the responsibilities for managing emergency situations and returning the network to a safe and compliant state. The process for remedying risky situations or defective assets lies directly with Wayne and	Andrew said that investigation of faults can lead to more comprehensive engineering studies to determine whether a systemic defect exists, components are prematurely aging etc. It was also noted that SWER brackets have been altered to minimise the risk of live conductors falling to ground as happened in North Canterbury.	Widely used AM standards require that the organisation establishes implements and maintains process(es) for the handling and investigation of failures incidents and non-conformities for assets and sets down a number of expectations. Specifically this question examines the requirement to define clearly responsibilities and authorities for these activities, and communicate these unambiguously to relevant people including external stakeholders if appropriate.	The organisation's safety and environment management team. The team with overall responsibility for the management of the assets. People who have appointed roles within the asset-related investigation procedure, from those who carry out the investigations to senior management who review the recommendations. Operational controllers responsible for managing the asset base under fault conditions and maintaining services to consumers. Contractors and other third parties as appropriate.	Process(es) and procedure(s) for the handling, investigation and mitigation of asset-related failures, incidents and emergency situations and non conformances. Documentation of assigned responsibilities and authority to employees. Job Descriptions, Audit reports. Common communication systems i.e. all Job Descriptions on Internet etc.

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

Company Name	Marlborough Lines
AMP Planning Period	1 April 2016 – 31 March 2026
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

Company Name	Marlborough Lines
AMP Planning Period	1 April 2016 – 31 March 2026
Asset Management Standard Applied	

Question No.	Function	Question	Maturity Level 0	Maturity Level 1	Maturity Level 2	Maturity Level 3	Maturity Level 4
88	Life Cycle Activities	How does the organisation establish implement and maintain process(es) for the implementation of its asset management plan(s) and control of activities across the creation, acquisition or enhancement of assets. This includes design, modification, procurement, construction and commissioning activities?	The organisation does not have process(es) in place to manage and control the implementation of asset management plan(s) during activities related to asset creation including design, modification, procurement, construction and commissioning.	The organisation is aware of the need to have process(es) and procedure(s) in place to manage and control the implementation of asset management plan(s) during activities related to asset creation including design, modification, procurement, construction and commissioning but currently do not have these in place (note: procedure(s) may exist but they are inconsistent/incomplete).	The organisation is in the process of putting in place process(es) and procedure(s) to manage and control the implementation of asset management plan(s) during activities related to asset creation including design, modification, procurement, construction and commissioning. Gaps and inconsistencies are being addressed.	Effective process(es) and procedure(s) are in place to manage and control the implementation of asset management plan(s) during activities related to asset creation including design, modification, procurement, construction and commissioning.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
91	Life Cycle Activities	How does the organisation ensure that process(es) and/or procedure(s) for the implementation of asset management plan(s) and control of activities during maintenance (and inspection) of assets are sufficient to ensure activities are carried out under specified conditions, are consistent with asset management strategy and control cost, risk and performance?	The organisation does not have process(es)/procedure(s) in place to control or manage the implementation of asset management plan(s) during this life cycle phase.	The organisation is aware of the need to have process(es) and procedure(s) in place to manage and control the implementation of asset management plan(s) during this life cycle phase but currently do not have these in place and/or there is no mechanism for confirming they are effective and where needed modifying them.	The organisation is in the process of putting in place process(es) and procedure(s) to manage and control the implementation of asset management plan(s) during this life cycle phase. They include a process for confirming the process(es)/procedure(s) are effective and if necessary carrying out modifications.	The organisation has in place process(es) and procedure(s) to manage and control the implementation of asset management plan(s) during this life cycle phase. They include a process, which is itself regularly reviewed to ensure it is effective, for confirming the process(es)/ procedure(s) are effective and if necessary carrying out modifications.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
95	Performance and condition monitoring	How does the organisation measure the performance and condition of its assets?	The organisation has not considered how to monitor the performance and condition of its assets.	The organisation recognises the need for monitoring asset performance but has not developed a coherent approach. Measures are incomplete, predominantly reactive and lagging. There is no linkage to asset management objectives.	The organisation is developing coherent asset performance monitoring linked to asset management objectives. Reactive and proactive measures are in place. Use is being made of leading indicators and analysis. Gaps and inconsistencies remain.	Consistent asset performance monitoring linked to asset management objectives is in place and universally used including reactive and proactive measures. Data quality management and review process are appropriate. Evidence of leading indicators and analysis.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
99	Investigation of asset-related failures, incidents and nonconformities	How does the organisation ensure responsibility and the authority for the handling, investigation and mitigation of asset-related failures, incidents and emergency situations and non conformances is clear, unambiguous, understood and communicated?	The organisation has not considered the need to define the appropriate responsibilities and the authorities.	The organisation understands the requirements and is in the process of determining how to define them.	The organisation are in the process of defining the responsibilities and authorities with evidence. Alternatively there are some gaps or inconsistencies in the identified responsibilities/authorities.	The organisation have defined the appropriate responsibilities and authorities and evidence is available to show that these are applied across the business and kept up to date.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.

<p>SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY</p> <p>This schedule requires information on the EDB'S self-assessment of the maturity of its asset management practices.</p>	Company Name	Marlborough Lines
	AMP Planning Period	1 April 2016 – 31 March 2026
	Asset Management Standard Applied	

<p>SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)</p>	Company Name	Marlborough Lines
	AMP Planning Period	1 April 2016 – 31 March 2026
	Asset Management Standard Applied	

Question No.	Function	Question	Score	Evidence—Summary	User Guidance	Why	Who	Record/document Information
105	Audit	What has the organisation done to establish procedure(s) for the audit of its asset management system (process(es))?	3	The Telarc audit reports for NZS 7901 and OHSAS 18001 were examined. It is noted that both of these reports have a range of working documents, charts, checklists and photos attached that Ian said he uses to improve practices between audits. It is observed that AM practices are regularly reviewed as part of both the AMMAT and PSMS activities.	Ian confirmed that the annual audits for the ISO 9001, 14001, 18001 and NZS 7901 overlap into the AM activity. Ian also confirmed that the Emergency Preparedness Plan is included in the ISO 9001 audit.	This question seeks to explore what the organisation has done to comply with the standard practice AM audit requirements (eg, the associated requirements of PAS 55 s 4.6.4 and its linkages to s 4.7).	The management team responsible for its asset management procedure(s). The team with overall responsibility for the management of the assets. Audit teams, together with key staff responsible for asset management. For example, Asset Management Director, Engineering Director. People with responsibility for carrying out risk assessments	The organisation's asset-related audit procedure(s). The organisation's methodology(s) by which it determined the scope and frequency of the audits and the criteria by which it identified the appropriate audit personnel. Audit schedules, reports etc. Evidence of the procedure(s) by which the audit results are presented, together with any subsequent communications. The risk assessment schedule or risk registers.
109	Corrective & Preventative action	How does the organisation instigate appropriate corrective and/or preventive actions to eliminate or prevent the causes of identified poor performance and non conformance?	3	The first step of preventing poor performance or non-conformance is the use of documents such as the Network Standard Drawings, the Network Design & Construction Standards, the Material Specification (in the AMP), and the suite of Procurement Documents (contract specifications etc). The second step of preventing non-conformance is the inspection of completed works (which Marlborough Lines has indicated that it needs to improve). Marlborough Lines	Andrew commented that works inspection could be improved. Andrew also commented that detail designs are peer reviewed by the Operations Manager to ensure that details haven't been overlooked.	Having investigated asset related failures, incidents and non-conformances, and taken action to mitigate their consequences, an organisation is required to implement preventative and corrective actions to address root causes. Incident and failure investigations are only useful if appropriate actions are taken as a result to assess changes to a businesses risk profile and ensure that appropriate arrangements are in place should a recurrence of the incident happen. Widely used AM standards also require that necessary changes arising from preventive or corrective action are made to the asset management system.	The management team responsible for its asset management procedure(s). The team with overall responsibility for the management of the assets. Audit and incident investigation teams. Staff responsible for planning and managing corrective and preventive actions.	Analysis records, meeting notes and minutes, modification records. Asset management plan(s), investigation reports, audit reports, improvement programmes and projects. Recorded changes to asset management procedure(s) and process(es). Condition and performance reviews. Maintenance reviews
113	Continual Improvement	How does the organisation achieve continual improvement in the optimal combination of costs, asset related risks and the performance and condition of assets and asset systems across the whole life cycle?	2.5	Section 9.1 of the AMP includes a detailed comparison of Marlborough Lines CapEx, OpEx and Reliability against both national averages and suitable peers. Marlborough Lines also seeks to improve its AM practices by on-going use of the AMMAT. In regard to continually improving asset performance and in-service failure risk, the establishment of the live operating ban on Long & Crawford oil switches is a good example.	Wayne commented that KPI's around asset performance are discussed every month. Wayne commented that the public risk exposure for the remaining Long & Crawford oil switches is considered very low due to their remote location and low fault level, and that if it had been in Blenheim it would have removed long ago.	Widely used AM standards have requirements to establish, implement and maintain process(es)/procedure(s) for identifying, assessing, prioritising and implementing actions to achieve continual improvement. Specifically there is a requirement to demonstrate continual improvement in optimisation of cost risk and performance/condition of assets across the life cycle. This question explores an organisation's capabilities in this area—looking for systematic improvement mechanisms rather than reviews and audit (which are separately examined).	The top management of the organisation. The manager/team responsible for managing the organisation's asset management system, including its continual improvement. Managers responsible for policy development and implementation.	Records showing systematic exploration of improvement. Evidence of new techniques being explored and implemented. Changes in procedure(s) and process(es) reflecting improved use of optimisation tools/techniques and available information. Evidence of working parties and research.

Company Name	Marlborough Lines
AMP Planning Period	1 April 2016 – 31 March 2026
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY

This schedule requires information on the EDB's self-assessment of the maturity of its asset management practices.

115	Continual Improvement	How does the organisation seek and acquire knowledge about new asset management related technology and practices, and evaluate their potential benefit to the organisation?	3	Various technical magazines, EEA guidelines and course notes, and consultants publications have been examined.	Geoff said that a wide range of legal and regulatory advice is received from statutory bodies and consultants, ensuring the Marlborough Lines is able to amend its AM practices to comply (an example was the requirement to comply with the Electricity (Safety) Regulations 2010 that required a PSMS). Andrew commented that the EEA provides advice, EEA courses, trade shows, conferences, magazines, technical bulletins, research papers etc.	One important aspect of continual improvement is where an organisation looks beyond its existing boundaries and knowledge base to look at what 'new things are on the market'. These new things can include equipment, process(es), tools, etc. An organisation which does this (eg, by the PAS 55 s 4.6 standards) will be able to demonstrate that it continually seeks to expand its knowledge of all things affecting its asset management approach and capabilities. The organisation will be able to demonstrate that it identifies any such opportunities to improve, evaluates them for suitability to its own organisation and implements them as appropriate. This question explores an organisation's approach to this activity.	The top management of the organisation. The manager/team responsible for managing the organisation's asset management system, including its continual improvement. People who monitor the various items that require monitoring for 'change'. People that implement changes to the organisation's policy, strategy, etc. People within an organisation with responsibility for investigating, evaluating, recommending and implementing new tools and techniques, etc.	Research and development projects and records, benchmarking and participation knowledge exchange professional forums. Evidence of correspondence relating to knowledge acquisition. Examples of change implementation and evaluation of new tools, and techniques linked to asset management strategy and objectives.
-----	-----------------------	---	---	--	--	---	--	---

Company Name AMP Planning Period Asset Management Standard Applied	Marlborough Lines
	1 April 2016 – 31 March 2026
SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)	

Company Name AMP Planning Period Asset Management Standard Applied	Marlborough Lines
	1 April 2016 – 31 March 2026
SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)	

Question No.	Function	Question	Maturity Level 0	Maturity Level 1	Maturity Level 2	Maturity Level 3	Maturity Level 4
105	Audit	What has the organisation done to establish procedure(s) for the audit of its asset management system (process(es))?	The organisation has not recognised the need to establish procedure(s) for the audit of its asset management system.	The organisation understands the need for audit procedure(s) and is determining the appropriate scope, frequency and methodology(s).	The organisation is establishing its audit procedure(s) but they do not yet cover all the appropriate asset-related activities.	The organisation can demonstrate that its audit procedure(s) cover all the appropriate asset-related activities and the associated reporting of audit results. Audits are to an appropriate level of detail and consistently managed.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
109	Corrective & Preventative action	How does the organisation instigate appropriate corrective and/or preventive actions to eliminate or prevent the causes of identified poor performance and non conformance?	The organisation does not recognise the need to have systematic approaches to instigating corrective or preventive actions.	The organisation recognises the need to have systematic approaches to instigating corrective or preventive actions. There is ad-hoc implementation for corrective actions to address failures of assets but not the asset management system.	The need is recognized for systematic instigation of preventive and corrective actions to address root causes of non compliance or incidents identified by investigations, compliance evaluation or audit. It is only partially or inconsistently in place.	Mechanisms are consistently in place and effective for the systematic instigation of preventive and corrective actions to address root causes of non compliance or incidents identified by investigations, compliance evaluation or audit.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
113	Continual Improvement	How does the organisation achieve continual improvement in the optimal combination of costs, asset related risks and the performance and condition of assets and asset systems across the whole life cycle?	The organisation does not consider continual improvement of these factors to be a requirement, or has not considered the issue.	A Continual improvement ethos is recognised as beneficial, however it has just been started, and covers partially the asset drivers.	Continual improvement process(es) are set out and include consideration of cost risk, performance and condition for assets managed across the whole life cycle but it is not yet being systematically applied.	There is evidence to show that continual improvement process(es) which include consideration of cost risk, performance and condition for assets managed across the whole life cycle are being systematically applied.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.

Company Name	Marlborough Lines
AMP Planning Period	1 April 2016 – 31 March 2026
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

115	Continual Improvement	How does the organisation seek and acquire knowledge about new asset management related technology and practices, and evaluate their potential benefit to the organisation?	The organisation makes no attempt to seek knowledge about new asset management related technology or practices.	The organisation is inward looking, however it recognises that asset management is not sector specific and other sectors have developed good practice and new ideas that could apply. Ad-hoc approach.	The organisation has initiated asset management communication within sector to share and, or identify 'new' to sector asset management practices and seeks to evaluate them.	The organisation actively engages internally and externally with other asset management practitioners, professional bodies and relevant conferences. Actively investigates and evaluates new practices and evolves its asset management activities using appropriate developments.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
-----	-----------------------	---	---	--	--	--	---